CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0694:203 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Fire Control Instruments, 301 2nd Avenue, Waltham, MA 02451-1133

Contact: Anthony J. Shalna (781) 471-3000*

DESIGN: Model 7200 Micro fire alarm control unit. Power-limited; coded, noncoded or marchtime,

> local; auxiliary, remote station, central station and proprietary signaling system; waterflow, releasing device and sprinkler supervision. Refer to listee's data sheet for additional detailed

product description and operational considerations. System components:

SPSU Power Supply

Keyboard Display Unit KDU-M, KDU-LM ALU-M Analog Loop Unit System Control Unit SCU-M

CAB-A Enclosure

RAU, RAUFV Remote Annunciator AMM-2, -4, -4S Monitor Module AOM, AOM-2 Output Module

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a high-rise fire alarm control unit for use with separately listed compatible initiating

and indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition.

Refer to manufacturer's Installation Manual for details.

*Rev. 06-11-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 11, 2002 Date Issued: Listing Expires June 30, 2003

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager